

FuelCAN FLC300

Fuel sender to J1939 CANbus interface

yi6494
revision A, 2015-06-03
section 80



Installation Instructions


Please read the following information before installing. A visual inspection of this product for damage during shipping is recommended before installation. It is your responsibility to ensure that qualified mechanical and electrical technicians install this product. If in doubt, please contact your local Murphy representative.

General Information

WARNING

BEFORE BEGINNING INSTALLATION OF THIS PRODUCT

- ✓ Disconnect all electrical power to the machine
- ✓ Make sure the machine cannot operate during installation
- ✓ Follow all safety warnings of the machine manufacturer
- ✓ Read and follow all installation instructions



FuelCAN is a compact interface for translating an analogue fuel level sender signal into digital SAE J1939 CANbus data. The device allows integration of standard fuel level senders into modern ECU-based engine instrument and control systems.

Standard FuelCAN modules have three inputs (only one of which is connected at any one time): input 1 is configured for use with Murphy ES series resistive fuel level senders; inputs 2 and 3 can be used with fuel level senders having compatible resistance ranges.

	fuel level / approx. resistance, Ohms				
	empty	1/4	1/2	3/4	full
Input 1 (Murphy)	240	147	96	60	33.5
Input 2	240	158	100	58	30
Input 3	10	56	95	138	180

FuelCAN inputs can also be factory-configured for use with non-standard fuel level or resistive senders. Please note that minimum order quantities apply for custom solutions.

A rear facing LED indicates input and CANbus status. FuelCAN is compact and light enough to be incorporated into wiring harnesses, but can also be surface mounted via four case holes. The polycarbonate case is fully sealed in epoxy resin for high impact and environmental resistance.

These instructions relate to Murphy part numbers:

Part code	Model/Description
79.70.0085	FuelCAN, no CAN terminating resistor
79.70.0095	FuelCAN, 120 Ohm CAN terminating resistor
79.70.0006	Previous code for 79.70.0095 above

FuelCAN modules with part codes other than above may include non-standard input scaling, CANbus/J1939 data parameters or wire numbers/colours – please check specifications with your Murphy representative.

Specifications

Power supply

Operating voltage, steady state: 7 to 35 VDC
Current consumption: 25mA (typ.)

Inputs

Maximum operating range: -2 to +35 VDC
Input 1 sender range, Ohms: 240 (empty) to 33.5 (full)
Input 2 sender range, Ohms: 240 (empty) to 30 (full)
Input 3 sender range, Ohms: 10 (empty) to 180 (full)

Output

CANbus:

SAE J1939 protocol, PGN65276 (00FEFC₁₆), 2 sec update rate.
Source address: 0xA0
Optional 120 Ohm terminating resistor (see part codes below left).


Physical

Case material: high impact ABS, epoxy filled
Dimensions: see diagram below
Weight: approx 60g / 0.13 lb
Operating temperature: -20 to +85 °C / -4 to +185 °F
Environmental sealing: IP65, exposed lead ends
Electromagnetic compatibility: 2004/108/EC

Connection and Dimensions

(standard FLC300 shown)

Dimensions in mm (in.) for reference only. Use actual product for template.



Electrical Connection & Mounting

Electrical Connection

FuelCAN connection is via 8 colour-coded flying leads (see diagram on page 1).

RED: Power supply positive DC

BLACK: Power supply negative DC

Connect these wires to a smooth DC power supply in the range 7 to 35 VDC. A 1 Amp anti-surge fuse is recommended in the positive DC line.

FuelCAN operates with negative earth/ground or fully insulated DC systems. **DO NOT** use FuelCAN with positive earth/ground systems.

YELLOW: CANbus high

GREEN: CANbus low

Connect these wires to the engine's CANbus, using the appropriate twisted-pair cable to J1939 specification. Part code 79.70.0095 includes a non-removable 120 Ohm CAN terminating resistor. Part code 79.70.0085 does not include any CAN resistor. For other FuelCAN part codes, check with your Murphy representative.

BLACK: Sender common (negative DC)

VIOLET: Sender input 1 (Murphy)

ORANGE: Sender input 2

WHITE: Sender input 3

For best measurement accuracy, use an insulated return (2-wire) resistive fuel level sender, e.g. (for input 1) Murphy ES2F series. Connect one sender terminal to the appropriate FuelCAN input lead (1, 2 or 3); connect the other sender terminal to FuelCAN's Sender Common (black) wire.

Where a 1-wire (negative DC/ground return) sender is used, connect the black (sender common) wire to battery negative.

Mounting

FuelCAN uses an epoxy-resin filled, polycarbonate case for high impact and environmental resistance. The case is compact and light enough for inclusion in (or tie-wrapping to) an engine wiring harness; or, using the actual product as a template, FuelCAN can be surface mounted via four M4 (0.15 in) holes (see diagram on page 1 for approximate dimensions). The case is sealed to IP65; the exposed flying leads must use connectors appropriate for the environmental sealing required.

Operation and Maintenance

Operation

At each power up, FuelCAN checks all three inputs for an in-range sender resistance. If more than one sender is connected at power-up, FuelCAN prioritises input selection in the order 1 (Murphy), 2 then 3.

Once FuelCAN has selected a valid input, it continues to use that input until the DC power supply is cycled. FuelCAN transmits fuel level data every 2 seconds, from CAN address 0xA0. Data specification is otherwise as SAE J1939-71:

PGN	65276 (00FEFC ₁₆)
Message data length	8 bytes
Relevant byte	#2 (fuel level)
Data page	0
PDU format	254
PDU specific	252
Resolution	0.4%/bit gain, 0% offset
Data range	0 to 100%

If a sender failure (short or open circuit) occurs during operation, FuelCAN transmits fuel level data of value 0xFE₁₆ (indicating 'measurement error').

If no valid sender is detected at power-up, FuelCAN transmits a value 0xFF₁₆ (indicating 'measurement not available') and flashes its LED in a 'heartbeat' pattern (two short pulses, followed by a longer pause). J1939 message PGN65275 also includes bytes for other parameters, including washer fluid level (byte #1),

fuel filter differential pressure (byte #3), engine oil filter differential pressure (byte #4) and cargo ambient temperature (bytes #5/6). For each of these parameters, FuelCAN transmits a value 0xFF₁₆ (indicating 'measurement not available').

LED operation is as follows:

LED pattern	Status
Off	Power off
Flashing ('heartbeat' pulse on)	Power on, but all inputs open circuit (valid sender not detected).
Flashing (50/50% on/off)	Power on, valid sender input, but no CAN activity.
On	Power on, valid sender input and CAN activity

Maintenance and Warranty

FuelCAN contains no user-serviceable parts. Maintenance is therefore limited to the following preventative checks:

- Check that FuelCAN electrical connections are secure.
- Check that the case is mounted securely, with vibration and environmental exposure minimised where possible. The case may be wiped with a clean, damp cloth. Do not use cleaning solvents.

FuelCAN is supplied with a two year warranty on parts and workmanship. In the event of a fault or technical query, and before returning equipment, please contact your Murphy representative for technical support.

ENOVATION CONTROLS CORPORATE HEADQUARTERS
5311 S 122ND EAST AVENUE, TULSA, OK 74146, USA

ENOVATION CONTROLS - SAN ANTONIO OFFICE
5757 FARINON DRIVE, SAN ANTONIO, TX 78249, USA

ENOVATION CONTROLS - HOUSTON OFFICE
105 RANDON DYER RD, ROSENBERG, TX 77471, USA

ENOVATION CONTROLS LTD. - UNITED KINGDOM
CHURCH ROAD, LAVERSTOCK, SALISBURY, SP1 1GZ, UK

MURPHY ECONTROLS TECHNOLOGIES - CHINA
77 23RD STREET, HANGZHOU ECONOMIC &
TECHNOLOGICAL DEVELOPMENT AREA,
HANGZHOU, ZHEJIANG 310018, CHINA

SALES & SUPPORT, NORTH AMERICA

MURPHY PRODUCTS:
PHONE: 918 317 4100
FAX: 918 317 4266
EMAIL: SALES@FWMURPHY.COM
WWW.FWMURPHY.COM

ECONTROLS PRODUCTS:
PHONE: 210 495 9772
FAX: 210 495 9791
EMAIL: INFO@ECONTROLS.COM
WWW.ECONTROLS.COM

MURPHY CONTROL SYSTEMS & SERVICES
PHONE: 281 633 4500
FAX: 281 633 4588
EMAIL: CSS-SOLUTIONS@FWMURPHY.COM

MURPHY INDUSTRIAL PANEL DIVISION
PHONE: 918 317 4100
FAX: 918 317 4124
EMAIL: IPDSALES@FWMURPHY.COM

SALES & SUPPORT, INTERNATIONAL

EUROPE, MIDDLE EAST & AFRICA
PHONE: +44 1722 410055
FAX: +44 1722 410088
EMAIL: SALES@ENOVATIONCONTROLS.EU
WWW.FWMURPHY.EU

CHINA
PHONE: +86 571 9798 6060
FAX: +86 571 8684 8878
EMAIL: APSALES@FWMURPHY.COM

LATIN AMERICA & CARIBBEAN
PHONE: +1 918 317 2500
EMAIL: LASALES@FWMURPHY.COM

SOUTH KOREA
PHONE: +82 70 7951 4100
EMAIL: SKOREASALES@FWMURPHY.COM

INDIA
PHONE: +91 91581 37633
EMAIL: INDIASALES@FWMURPHY.COM



FM 28221 (Tulsa, OK - USA)
FM 28221 (Rosenberg, TX - USA)
FM 620667 (San Antonio, TX - USA)
FM 29422 (UK)



FM 523851, TS 589322 (China)